

---

# PROPOSED AMENDMENT TO FIRE LANE ORDINANCE #00-29

---

***REVISE SECTION 6 TO THE FOLLOWING:***

“Fire Lanes for other Premises

Fire Lanes shall access all but 1 side of the building to allow for apparatus to drive around the building.

The edge of the Fire Lane travel surface shall be ten (10) feet from the building, and the “building band” shall be clear of all obstructions except for minor landscaping which shall not be placed in front of windows or building fire equipment, and shall be maintained at a height less than four (4) feet. The building band shall be level or sloped not greater than twenty (20%).”